

APR. 2 1961

MASTER

Copy No 19

**APAE - 35**  
**Supplement 2**

AEC Research and  
Development Report  
UC-81, Reactors - Power  
[Special Distribution]

**shielding measurements at the**  
**SM-1 reactor**  
**(june 1961)**

Contract No. AT[30-1]-2639  
with U. S. Atomic Energy Commission  
New York Operations Office



**ALCO PRODUCTS, INC.**  
NUCLEAR POWER ENGINEERING DEPARTMENT

## **DISCLAIMER**

**This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.**

## **DISCLAIMER**

**Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.**

APAE-35  
Supplement 2  
Copy No.  
AEC Research and  
Development Report  
UC-81, Reactors, Power  
(Special Distribution)

**SHIELDING MEASUREMENTS AT THE SM-1 REACTOR  
(JUNE 1961)**

By:  
F. G. Moote  
C. H. Obrist

Approved by:  
M. H. Dixon, Project Engineer

Issued: March 16, 1962

Contract No. AT(30-1)-2639  
with U. S. Atomic Energy Commission  
New York Operations Office

**ALCO PRODUCTS, INC.**  
Nuclear Power Engineering Department  
Post Office Box 414  
Schenectady 1, N. Y.



### AEC LEGAL NOTICE

This report was prepared as an account of Government sponsored work. Neither the United States, nor the Commission, nor any person acting on behalf of the Commission:

A. Makes any warranty or representation, expressed or implied, with respect to the accuracy, completeness, or usefulness of the information contained in this report, or that the use of any information, apparatus, method, or process disclosed in this report may not infringe privately owned rights: or

B. Assumes any liabilities with respect to the use of, or for damages resulting from the use of any information, apparatus, method, or process disclosed in this report.

As used in the above, "person acting on behalf of the Commission" includes any employee or contractor of the Commission, or employee of such contractor, to the extent that such employee or contractor of the Commission, or employee of such contractor prepares, disseminates, or provides access to, any information pursuant to his employment or contract with the Commission, or his employment with such contractor.

### ALCO LEGAL NOTICE

This report was prepared by Alco Products, Incorporated in the course of work under, or in connection with, Contract No. AT(30-1)-2639, issued by U. S. Atomic Energy Commission, New York Operations Office; and subject only to the rights of the United States, under the provisions of this contract, Alco Products, Incorporated makes no warranty or representation, express or implied, and shall have no liability with respect to this report or any of its contents or with respect to the use thereof or with respect to whether any such use will infringe the rights of others.

DISTRIBUTION

External  
Copies

- 1 - 2 New York Operations Office  
U. S. Atomic Energy Commission  
376 Hudson Street  
New York 14, New York  
  
Attention: I. M. Adler
- 3 New York Operations Office  
U. S. Atomic Energy Commission  
376 Hudson Street  
New York 14, New York  
  
Attention: Library
- 4 - 6 U. S. Atomic Energy Commission  
Washington 25, D. C.  
  
Attention: Chief, Water Systems Project  
Branch (Army Reactors)  
Division of Reactor Development  
Mail Station F-311
- 7 U. S. Atomic Energy Commission  
Washington 25, D. C.  
  
Attention: Chief, Evaluation and  
Planning Branch  
Civilian Reactors  
Div. of Reactor Development  
Mail Station F-311
- 8 U. S. Atomic Energy Commission  
Chief, New York Patent Group  
Brookhaven National Laboratory  
Upton, New York  
  
Attention: Harman Potter
- 9 Idaho Nuclear Power Field Office  
U. S. Army Engineer Reactors Group  
P. O. Box 2108  
Idaho Falls, Idaho

DISTRIBUTION (CONT'D)

External  
Copies

- 10 U. S. Atomic Energy Commission  
Reports and Statistics Branch  
Division of Reactor Development  
Washington 25, D. C.
- 11 - 12 Office of the Chief of Engineers  
Department of the Army  
Building T-7  
Washington 25, D. C.  
  
Attention: Chief, Projects Branch  
Nuclear Power Division
- 13 - 15 Nuclear Power Field Office  
U. S. Army Engineer Reactors Group  
Fort Belvoir, Virginia  
  
Attention: Chief, Nuclear Power  
Field Office
- 16 Nuclear Power Field Office  
U. S. Army Engineer Reactors Group  
Fort Belvoir, Virginia  
  
Attention: O. I. C. SM-1
- 17 Chief, U. S. Army Reactors Group  
Fort Greely, Alaska  
APO 733  
Seattle, Washington  
  
Attention: O. I. C. SM-1A
- 18 Commanding Officer  
U. S. Army Polar Research  
and Development Center  
Fort Belvoir, Virginia  
  
Attention: Nuclear Power Officer
- 19 - 21 Office of Technical Information Extension  
P. O. Box 62  
Oak Ridge, Tennessee

DISTRIBUTION (CONT'D)

External  
Copies

- 22      Union Carbide Nuclear Corporation  
         Oak Ridge National Laboratory  
         Y-12 Building 9704-1  
         P. O. Box "Y"  
         Oak Ridge, Tennessee  
  
         Attention: L. D. Schaffer
- 23      The Martin Company  
         P. O. Box 5042  
         Middle River, Maryland  
  
         Attention: AEC Contract Document Custodian
- 24 - 25      Combustion Engineering, Incorporated  
         Nuclear Division  
         Prospect Hill Road  
         Windsor, Connecticut  
  
         Attention: Mr. J. B. Anderson
- 26      Alco Products, Inc.  
         Post Office Box 145  
         Fort Belvoir, Virginia  
  
         Attention: W. C. Best

Internal  
Copies

- |    |                 |         |                                |
|----|-----------------|---------|--------------------------------|
| 27 | K. Kasschau     | 39      | L. D. Stephenson               |
| 28 | J. G. Gallagher | 40      | C. R. Bergmann                 |
| 29 | J. F. Haines    | 41      | R. E. Neville                  |
| 30 | M. H. Dixon     | 42 - 43 | Shielding & Hazards Group File |
| 31 | P. E. Bobe      | 44      | Criticality Facility File      |
| 32 | J. M. Ravets    |         |                                |
| 33 | W. T. Williams  | 45      | C. H. Obrist                   |
| 34 | S. Pacino       |         | Barr Building                  |
| 35 | S. N. Kemp      |         | 910 Seventeenth St. NW         |
| 36 | F. G. Moote     |         | Washington 6, D. C.            |
| 37 | J. F. Scoles    |         |                                |
| 38 | J. R. Coombe    | 46 - 50 | NPED File                      |

THIS PAGE  
WAS INTENTIONALLY  
LEFT BLANK

## ABSTRACT

Neutron flux and gamma radiation measurements through the SM-1 primary shield were made at the startup of Core II in June 1961. They extend previous measurements (APAE-35) both vertically and horizontally in the primary shield and in the rod drive pit. Dose rate measurements on spent fuel elements under water are also reported.

THIS PAGE  
WAS INTENTIONALLY  
LEFT BLANK

## TABLE OF CONTENTS

	<u>Page</u>
ABSTRACT -----	vii
1.0 SUMMARY -----	1
2.0 INTRODUCTION -----	3
2.1 Test Description -----	3
3.0 NEUTRON FLUX MEASUREMENTS -----	7
3.1 Neutron Flux in Instrument Well A - Test A403 -----	8
3.2 Neutron Flux in Primary Shield - Test A401 -----	8
3.3 Fast-Flux Measurements -----	10
4.0 GAMMA RADIATION MEASUREMENTS -----	25
4.1 Gamma Flux in Instrument Well A - Test A404 -----	25
4.2 Gamma Flux in Primary Shield - Test A402 -----	25
4.3 Dose Rate at Vapor Container Shield Wall -----	29
4.4 Radiation Surveys in Rod Drive Pit - Test A407 -----	29
5.0 SPENT FUEL ELEMENT RADIATION MEASUREMENTS - TEST A408 -----	41
6.0 CONCLUSIONS -----	43
7.0 RECOMMENDATIONS -----	45
7.1 Additional Shielding Tests -----	45
7.2 Analysis of Shielding Data -----	45
8.0 REFERENCES -----	47



THIS PAGE  
WAS INTENTIONALLY  
LEFT BLANK

## LIST OF FIGURES

<u>Figure</u>	<u>Title</u>	<u>Page</u>
3.1	Gold Foil Activation - Instrument Well A	6
3.2	Thermal Neutron Flux in SM-1 Primary Shield	13
3.3	Thermal Neutron Flux in SM-1 Primary Shield	15
3.4	Thermal Neutron Flux - Inner Shield Tank Axis SM-1	17
3.5	Thermal Neutron Flux in Rod Drive Pit and Outside Shield Tank	20
3.6	Thermal Neutron Flux Distribution in SM-1 Primary Shield	21
3.7	Fast Neutron Flux - SM-1 Primary Shield	23
3.8	Fast Neutron Flux - SM-1 Primary Shield	24
4.1	Gamma Radiation - Instrument Well A	28
4.2	Gamma Radiation Dose Rate in Reactor Channels and Well A	33
4.3	Gamma Radiation Dose Rate in Reactor Shield Channels and Well A	34
4.4	Gamma Radiation Dose Rate In Inner Shield Tank Axis	36
4.5	Gamma Radiation Distribution in SM-1 Primary Shield	37
4.6	Gamma Radiation Dose Rate In Vapor Container Shield	38
4.7	Gamma Radiation Dose Rate From Spent Fuel Elements	39

THIS PAGE  
WAS INTENTIONALLY  
LEFT BLANK

## LIST OF TABLES

<u>Table</u>	<u>Title</u>	<u>Page</u>
3.1	Cadmium Ratios, Epithermal Fraction and Effective Gold Cross Section	9
3.2	Thermal Neutron Flux Through Shield Rings	11
3.3	Thermal Neutron Flux Through Inner Shield Tank Axis	16
3.4	Thermal Neutron Flux Outside Shield Tank	18
3.5	Thermal Neutron Flux in Rod Drive Pit	19
3.6	Fast Neutron Flux In Shield Rings	22
4.1	Gamma Background In Instrument Well A	26
4.2	Gamma Radiation in Instrument Well A	27
4.3	Gamma Radiation in Shield Rings	31
4.4	Gamma Radiation in Inner Shield Tank Axis	35

## 1.0 SUMMARY

Neutron flux and gamma radiation measurements in the SM-1 reactor primary shield have been made to show leakage and attenuation patterns in vertical as well as horizontal directions. These measurements are shown as contour maps of neutron flux and gamma dose rates.

Thermal neutron flux mapping was done by irradiating bare and cadmium covered gold foils in the water channels of the shield tanks and in the rod drive pit. Fast neutron flux in the outer shield tank was measured by irradiation of sulfur pellets.

Gamma radiation dose rates were measured by irradiation of film badge packs in the shield tanks. Dose rate surveys were made in the rod drive pit. High gamma radiation levels observed in the rod drive pit are attributed to high neutron flux in this area. The radiation from spent fuel elements during handling operations was measured above the water surface in the rod drive pit and agreed well with calculated values.

These measurements generally confirmed previous results reported in APAE-35 in respect to the shape of the flux distributions. In magnitude, however, the recent measurements were generally higher by a factor of three than were those shown by the previous results.

Recommendations are made for further studies of neutron flux and gamma dose rates in the rod drive pit and for additional fast flux measurements. Also, analysis of the shielding data in this report should be made to insure continuing adequacy of the shielding.

THIS PAGE  
WAS INTENTIONALLY  
LEFT BLANK

## 2.0 INTRODUCTION

A series of shielding measurements made at the SM-1 Army Package Power Reactor has been performed under the Program Plan for Engineering Support and Development of Army Pressurized Water Reactors. \* The purpose of these measurements was to supplement and extend previous measurements reported in APAE-35 to assure safety of operation with optimum shielding design and to verify design methods.

The previous measurements were limited to radial traverses through the primary shield at a vertical level of the core midplane. However, additional data were required in the vertical as well as the radial direction in order that specifications could be accurately made for the heights above the core to which the shield has to be built at the various increasing radial distances from the core.

Since high levels of shutdown gamma dose rate in the rod drive pit interfere with maintenance on the drive components, it is important to know the distribution of gamma radiation. It was desirable to determine whether the source of activity in the SM-1 rod drive area was neutron induced or resulted from core shutdown gammas.

### 2.1 TEST DESCRIPTION

The measurements for this program were carried out as far as possible in accordance with the following test procedures:

TP-A401	Primary Shielding, Neutron Flux
TP-A402	Primary Shielding, Gamma Flux
TP-A403	Instrument Wells, Neutron Flux
TP-A404	Instrument Wells, Gamma Flux
TP-A406	Rod Drive Pit, Neutron Flux
TP-A407	Rod Drive Pit, Gamma Flux
TP-A408	Spent Fuel Element Transfer Dose Rate

---

\* AP Note-286, Item 4.4 (FY-61 Program), October 10, 1960, and AP Note-378, Subtask 5.3 (FY-62 Program), September 6, 1961.

The neutron flux measurements were made by activating gold foils mounted on aluminum strips. These strips were inserted in the water channels of the primary shield, in the inner shield tank above the vessel cover, on the outside of the shield tank, in instrument well A, and in the rod drive pit. At each location, some of the gold foils were cadmium covered to make corrections for the epithermal neutron flux. Sulfur pellets also were inserted in the primary shield channels to measure the fast flux by the S (n, p) reaction. (E 2.9 Mev)

Gamma radiation measurements were made by irradiating film badges in polyethylene bags mounted on aluminum strips. These strips were inserted in the water channels of the primary shield, in the inner shield tank, and in instrument well A. A portable survey meter was used for radiation measurements in the rod drive pit. Dose rate measurements were made just above the water surface in the spent fuel pit during handling and transfer of fuel elements under water, with various depths of water shielding.

Four reactor power runs were used for these tests, plus a gamma background run before Core II startup. They were planned to obtain continuity and overlap for film-badge and foil activation and are identified as follows:

Run 0 - Before startup for 8.0 hr on June 7, 1961. Film badges were placed in instrument well A to obtain background measurement.

Run 1 - Average power 11.1 kw for 20 min June 10, 1961. Film badges were placed in shield slots 1, 2, 3 and 4, and in instrument well A. (2.75 hr total exposure)

Run 2 - Average power 26.6 kw for 8.0 hr June 10, 1961. (12.5 hr in reactor shield) Film badges were placed in shield slots 1, 2, 3 and 4, and in instrument well A. (12.5 hr total exposure)

Run 3 - Average power 237 kw for 60 hr June 10-14, 1961. Film badges were placed in the inner shield tank. Foils were placed in shield slots 4, 5, 6 and 7, and in the inner shield tank. (93 hr total exposure)

Run 4 - Average power 10.8 Mw for 64 hr June 14-24, 1961. Foils were left in place from Run 3, above in shield slots 4, 5, 6 and 7, and in inner shield tank. In addition, foils were placed outside the shield tank and in the rod drive pit. Sulfur pellets and foils were placed in shield slots 1, 3 and 6. (10 days total exposure)

There was difficulty in determining the power level of runs 1, 2 and 3 because the nuclear instruments, particularly the Log N channel, had not been properly repositioned and recalibrated at startup of SM-1 Core II. During the early part of Run 4, the Log N ion chamber was raised on six different days by a total of 17 in. ; and after the full power run, it was again raised 1 in. for



its final adjustment. The Log N power-level correction was determined by three methods. At the end of Run 3, the generator was operated briefly at a load of 400 kw, and the Log N reading was about 200 percent, which was too high by about a factor of 5. The  $\Delta T$  integrator was recalibrated during Run 3 and was started up at the beginning of Run 4 for Core II operation.

The integrator reading was used as the correct energy output for Run 4. The thermal energy output for each day was compared with the value obtained by integrating the Log N chart readings to obtain a correction factor for the initial position of the ion chamber (Runs 1, 2 and 3) and for each of the six positions during Run 4. Finally, the flux distribution curve in instrument well A, Fig. 3.1, was used to determine an improved Log N correction factor for each of the seven positions. The final correction factor to the Log N readings for Runs 1, 2 and 3 was 0.222. This gives a power level believed to be within 50 percent of the correct value.



Figure 3.1. Gold Foil Activation  
Instrument Well "A"

Test A403  
10 June, 1962

Gold Foil Activation (cpm)

$10^4$

$10^3$

$10^2$

10


Bottom of Instrument Well A

Bare Gold Foils

Cadmium  
Covered  
Gold Foils

Vertical Distance From Core  $\xi$  (inches)

-20 -10 0 10 20 30 40 50





### 3.0 NEUTRON FLUX MEASUREMENTS

The earlier gold foil activations reported in APAE-35<sup>(1)</sup> were done at only one elevation, the core centerline. They were not reduced to absolute flux measurements, but the relative activities were normalized to agree with flux calculations using the VALPROD computer code.

In the present measurements, bare and cadmium covered gold foils were inserted at several elevations in the shield sections, as well as along the inner shield tank axis, outside the shield tank, and in the rod drive pit, in order to explore the flux pattern more completely. An attempt was made to reduce the activation measurements to absolute flux measurements, although many uncertain factors were involved.

The activated gold foils were removed and counted on the single channel analyzer at the SM-1 reactor; then they were shipped to the Alco Criticality Facility at Schenectady where those from Run 2 were counted again. The latter counter efficiency was known to be 2.39 percent from previous measurements with a standard foil. The SM-1 counting data for Run 4 was normalized to agree with the critical facility counting data for Run 2. The SM-1 counter efficiency and background were widely different for each run, so that no standard values could be used.

The usual relationship for thermal flux and foil activity was used:

$$\frac{\text{Activity (cps)}}{\text{mass (gm) x efficiency}} = \frac{\sigma N_0 \phi}{A} (1 - e^{-\lambda T}) e^{-\lambda t}$$

where:

- $\sigma$  = effective activation cross section for gold foil
- $N_0$  = Avogadro's number =  $6.023 \times 10^{24}$  gm-mole
- $A$  = atomic weight of  $\text{Au}^{197}$  = 197 gm-mole
- $\phi$  = thermal neutron flux at 2200 m/sec
- $\lambda$  = decay constant for  $\text{Au}^{198}$  =  $.0107 \text{ hr}^{-1}$
- $T$  = time of irradiation for run
- $t$  = time of decay from shutdown to counting

The use of an effective cross section is described in ANL-5800. (2) Corrections are made for a Maxwellian flux distribution, neutron temperature as affected by flux hardening, an epithermal flux index, and an effective resonance integral. Additional corrections were made for self-shielding in the gold foil: for both thermal and resonance energies and for epithermal shielding by the cadmium covers, as described in Section 8 of ANL-5800. (2)



The effective cross section can be written as:

$$\bar{\sigma} = \sigma_o (g + rs)$$

or with self-shielding factors

$$\bar{\sigma} = \sigma_o (g F_o + rs F_{res})$$

where:

$\sigma_o$	= cross section for 2200 m/sec neutrons
$g$	= correction for Maxwellian flux at temp. T
$F_o$	= thermal self-shielding factor = 0.93
$r$	= epithermal neutron density fraction
$s$	= a form of effective resonance integral, at temp. T
$F_{res}$	= resonance self-shielding factor = 0.56

The epithermal fraction  $r$  is determined from the cadmium ratio (bare-foil activity/cadmium covered foil activity). Table 3.1 shows the cadmium ratio, epithermal fraction, and effective cross section at various positions in the shielding. The effective cross section was first calculated for instrument well A, where it was found to be  $98.3 \times 2.56$  barns. This value was used to calculate all the thermal flux values tabulated and plotted in this report. Correction factors at various positions in the shield can be determined from Table 3.1.

### 3.1 NEUTRON FLUX IN INSTRUMENT WELL A - TEST A403

Gold foils, both bare and cadmium covered, were mounted on a 3 in. wide aluminum strip, which fitted loosely across the diameter of an instrument well, and were lowered into well A for Run 2. The strip was oriented perpendicular to the radius from the core centerline, so that all foils were close to the same radial distance of 36.37 in. from the core center. Bare and cadmium covered foils at the same elevation were spaced 3 in. apart (the width of the strip) to avoid interference by flux depression.

The positions and relative activities in counts per minute are shown in Table 3.2 and Fig. 3.1. The cadmium ratio (bare foil activity/cadmium covered foil activity) averaged 1.46. The activities have been converted to thermal flux at 10 Mw, and are included with the flux measurements of the following section.

### 3.2 NEUTRON FLUX IN PRIMARY SHIELD - TEST A401

Gold foils were mounted on aluminum strips and inserted into the 1 in. water channels between the 2 in. steel shield rings in the outer shield tank. A strip was inserted in each of channels 1, 2, 3 and 4 for Run 2, and in channels 4, 5, 6 and 7 as well as the inner shield tank axis for Runs 3 and 4. For Run 4 another strip of foils was mounted outside the shield tank at a position behind



**TABLE 3.1**  
CADMIUM RATIOS, EPITHERMAL FRACTION AND EFFECTIVE  
GOLD CROSS SECTION

<u>Position</u>	<u>Rod</u>	<u>r</u>	<u><math>\sigma</math></u>
Instrument Well A	1.46 to 1.5	0.154	98.3 x 2.56
Shield Channel 1	<u>1.8</u> to 2.0	0.103	2.03
Shield Channel 2	1.85 to 2.5		
Shield Channel 3	<u>2.0</u> to 2.3	0.080	1.79
Shield Channel 4	1.85 to <u>2.5</u>	0.054	1.51
Shield Channel 4	2.3 to 2.8		
Shield Channel 5	<u>3.0</u> to 3.2	0.041	1.37
Shield Channel 6	3.5 to 3.0		
Shield Channel 7	1.8 to 1.8		



the steam generator and near the corner of the rod drive pit. Several other foils were mounted in the rod drive pit in positions previously used for gamma radiation measurements on the 4 in. by 4 in. wood shield and on the water box face.

The positions of the foils, their activity, and the calculated thermal neutron flux at 10 Mw are shown in Tables 3.2 to 3.5 and Fig. 3.2 to 3.6. Figure 3.2 shows that the peak flux is about 4 in. below the core centerline and that the slope of the vertical attenuation curves is steeper above the core than below it. There was evidently a positioning error for the strip of foils in channel 2, so that all points in this channel were adjusted by 8 in. to fit the other curves. Figure 3.3 shows the radial attenuation through the shield at each elevation. These flux values differ in magnitude from the results in APAE-35, (1) Fig. 1.3 and are generally higher by a factor of 3 to 5 than the previous measurements, as normalized on the inner shield tank axis are shown in Table 3.3 and Fig. 3.4. Only the three lower foils had activities significantly above background; hence, the flux distribution is not very well defined.

The flux measurements on the outside of the shield tank and in the rod drive pit are shown in Tables 3.4 and 3.5 and in Fig. 3.5. The neutron flux in the rod drive pit was much higher than expected and could account for some activation of components and the observed gamma radiation levels. Previous measurements reported in APAE Memo-237(3) are approximately a factor of 10 lower and those in APAE-18(4) are a factor of 100 lower. The foils outside the shield tank were located close to one corner of the rod drive pit, and the shape of the vertical flux distribution curve indicates a neutron source from below, i. e. in the rod drive pit rather than from the reactor core.

All the flux measurements are shown in Fig. 3.6 as flux contours in the primary shield structure.

### 3.3 FAST FLUX MEASUREMENTS

Sulfur pellets were mounted on aluminum strips and inserted in shield channels 1, 3 and 6 for Run 4. The pellets were sent to the Alco Criticality Facility laboratory at Schenectady for measurement of activity and calculation of the fast flux ( $E_n > 2.9$  Mev) from the  $S^{32}(n,p)P^{32}$  reaction. The results are shown in Table 3.6 and in Fig. 3.7 and 3.8.

Some gold foils were also mounted on the strips in channels 3 and 6, as shown in Table 3.2, but the activities were inconsistent with each other and with the other runs.



TABLE 3.2  
THERMAL NEUTRON FLUX THROUGH SHIELD RINGS

Run 2 - 8.0 Hr at 26.6 Kw

Vertical Position From Core Centerline, In.	Activity, Cpm	Background, Cpm	Act. Net, Cpm	Decay Time, Hr	$e^{-\lambda t}$	Foil Mass, Gm	Neutron Flux at 10 Mw, N/cm <sup>2</sup> sec	
INSTRUMENT WELL A								
-18	9882	163	9719	111.2	3.28	.0314	$4.22 \times 10^9$	
-12	12790	163	12627	111.1	3.28	.0314	$5.48 \times 10^9$	
-6	14244	163	14081	111.0	3.28	.0314	$6.12 \times 10^9$	
0	13660	163	13497	111.1	3.28	.0314	$5.87 \times 10^9$	
+6	10967	163	10804	111.0	3.28	.0314	$4.69 \times 10^9$	
+12	6717	163	6554	111.0	3.28	.0314	$2.85 \times 10^9$	
+18	4127	163	3964	111.2	3.28	.0314	$1.73 \times 10^9$	
+30	1249	163	1086	111.3	3.28	.0314	$4.72 \times 10^8$	
+54	225	163	62	111.0	3.28	.0314	$2.69 \times 10^7$	
+72	184	163	21	111.0	3.28	.0314	$9.12 \times 10^6$	
SHIELD CHANNEL #1								
-29	6134	163	5971	110.033	3.25	.0311	$2.58 \times 10^9$	
-12	26716	163	26553	110.083	3.25	.0311	$1.15 \times 10^{10}$	
0	39731	163	39568	110.05	3.25	.0311	$1.72 \times 10^{10}$	
+12	21299	163	21136	110.017	3.25	.0311	$9.18 \times 10^9$	
+30	3738	163	3575	110.117	3.25	.0311	$1.55 \times 10^9$	
+54	512	163	349	110.15	3.25	.0311	$1.51 \times 10^8$	
+72	184	163	21	109.982	3.25	.0311	$9.12 \times 10^6$	
corr	SHIELD CHANNEL #2							
-29	-21	5560	163	5397	109.8	3.24	.0317	$2.29 \times 10^9$
-12	-12	14868	163	14705	109.6	3.24	.0317	$6.25 \times 10^9$
0	+8	10711	163	10548	109.7	3.24	.0317	$4.48 \times 10^9$
+12	+20	3482	163	3319	109.7	3.24	.0317	$1.41 \times 10^9$
+30	+38	502	163	339	109.7	3.24	.0317	$1.44 \times 10^8$
SHIELD CHANNEL #3								
-29		645	163	482	109.4	3.22	.0310	$2.08 \times 10^8$
-12		5468	163	5305	109.1	3.22	.0310	$2.29 \times 10^9$
0		6492	163	6329	109.1	3.22	.0310	$2.72 \times 10^9$
+12		2847	163	2684	109.1	3.22	.0310	$1.16 \times 10^9$
+30		369	163	206	109.3	3.22	.0310	$8.87 \times 10^7$
+54		184	163	21	109.2	3.22	.0310	$9.10 \times 10^6$
SHIELD CHANNEL #4								
-29		287	163	124	110.7	3.26	.0316	$5.33 \times 10^7$
-12		922	163	759	110.5	3.26	.0316	$3.26 \times 10^8$
0		1413	163	1250	110.6	3.26	.0316	$5.37 \times 10^8$
+12		983	163	820	110.4	3.26	.0316	$3.52 \times 10^8$
+30		276	163	113	110.4	3.26	.0316	$4.84 \times 10^7$
+54	Damaged							
+72	195	163	32	110.5	3.26	.0316	$1.37 \times 10^7$	



TABLE 3.2 (CONT'D)

Run 3 - 60 Hr at 237 Kw

Run 4 - 64 Hr at 10.8 Mw (Normalized to Run 2, Channel 4)


Vertical Position From Core Centerline, In.	Activity, Cpm	Background, Cpm	Act. Net, Cpm	Decay Time, Hr	$e^{-\lambda t}$	Foil Mass, Gm	Neutron Flux at 10 Mw, N/cm <sup>2</sup> sec
<u>SHIELD CHANNEL #4</u>							
-29	59479	504	58975	89.5	2.55	.0316	$3.65 \times 10^7$
-12	837515	504	837011	89.5	2.55	.0316	$5.12 \times 10^8$
0	870293	504	869789	89.5	2.55	.0316	$5.37 \times 10^8$ *Norm.
+12	584621	504	584117	89.5	2.55	.0316	$3.61 \times 10^8$
+30	29287	504	28783	89.5	2.55	.0316	$1.78 \times 10^7$
+54	953	504	449	89.5	2.55	.0316	$2.78 \times 10^5$
+72	699	504	195	89.5	2.55	.0316	$1.20 \times 10^5$
<u>SHIELD CHANNEL #5</u>							
-29	16173	541	15632	86.0	2.505	.0311	$9.5 \times 10^6$
-12	187035	541	186494	86.0	2.505	.0311	$1.13 \times 10^8$
0	256846	541	256305	86.0	2.505	.0311	$1.56 \times 10^8$
+12	107540	541	106999	86.0	2.505	.0311	$6.51 \times 10^7$
+30	6339	541	5798	86.0	2.505	.0311	$3.52 \times 10^6$
+54	611	541	70	86.0	2.505	.0311	$4.24 \times 10^4$
+72	nil	541				.0311	
<u>SHIELD CHANNEL #6</u>							
-29	4438	541	3897	86.75	2.513	.0317	$2.37 \times 10^6$
-12	23718	541	23177	86.75	2.513	.0317	$1.41 \times 10^7$
0	38754	541	38213	86.75	2.513	.0317	$2.33 \times 10^7$
+12	18788	541	18237	86.75	2.513	.0317	$1.11 \times 10^7$
+30	1806	541	1265	86.75	2.513	.0317	$7.71 \times 10^5$
+54	0	541					
+72	0	541					
<u>SHIELD CHANNEL #7</u>							
-29	1639	504	1135	90.0	2.558	.0310	$7.05 \times 10^5$
-12	5345	504	4841	90.0	2.558	.0310	$3.00 \times 10^6$
0	7147	504	6643	90.0	2.558	.0310	$4.11 \times 10^6$
+12	4120	504	3616	90.0	2.558	.0310	$2.24 \times 10^6$
+30	848	504	344	90.0	2.558	.0310	$2.13 \times 10^5$
+54	0	504					
+72	0	504					
<u>Run 4 - 64 Hr at 10.8 Mw (Normalized to Run 2 Channel 4)*</u>							
<u>SHIELD CHANNEL #3</u>							
-12	452533	504	452029	89.0	2.546	.0311	$2.79 \times 10^8$
+12	601451	504	600947	89.0	2.546	.0311	$3.71 \times 10^8$
+54	3332	504	2828	89.0	2.546	.0311	$1.75 \times 10^6$
+72	0						
<u>SHIELD CHANNEL #6</u>							
-12	54161	504	53657	89.0	2.546	.0311	$3.30 \times 10^7$
+12	36650	504	36146	89.0	2.546	.0311	$2.23 \times 10^7$
+54	nil	504					
+72	nil	504					

\* These gold foil measurements were intended for comparison with fast flux measurements (sulfur pellets), but data was inconsistent with each other and with other runs.




Figure 3.2. Thermal  
Neutron Flux in SM-1  
Primary Shield

Test A401  
June 10, 1961  
Gold Foil Activation  
Corrected to 10 MW Power









THIS PAGE  
WAS INTENTIONALLY  
LEFT BLANK

TABLE 3.3  
THERMAL NEUTRON FLUX THROUGH INNER SHIELD TANK AXIS

Run 3 - 60 Hr at 237 Kw

Run 4 - 64 Hr at 10.8 Mw (Normalized to Run 2, Channel 4)

Vertical Position From Core Centerline, In.	Activity, Cpm	Background, Cpm	Act. Net, Cpm	Decay Time, Hr	$e^{-\lambda t}$	Foil Mass, Gm	Neutron Flux at 10 Mw, $N/cm^2 \text{ sec}$
72	3690	504	3186	89.5	2.550	0.0310	$1.97 \times 10^6$
83	598	504	94	89.5	2.550	0.0310	$5.82 \times 10^4$
95	589	504	85				$5.23 \times 10^4$
107		504					
119		504					
143		504					
155		504					








TABLE 3.4  
THERMAL NEUTRON FLUX OUTSIDE SHIELD TANK

Run 4 - 64 Hr at 10.8 Mw (Normalized to Run 2, Channel 4)


Vertical Position From Core Centerline, In.	Activity, Cpm	Background, Cpm	Act. Net, Cpm	Decay Time, Hr	$e^{\lambda t}$	Foil Mass, Gm	Neutron Flux at 10 Mw, $N/cm^2 \text{ sec}$
-29	1792	541	1251	86.75	2.513	0.0311	$7.63 \times 10^5$
-12	1279	541	738	86.75	2.513	0.0311	$4.50 \times 10^5$
0	1047	541	506	86.75	2.513	0.0311	$3.09 \times 10^5$
+12	804	541	263	86.75	2.513	0.0311	$1.60 \times 10^5$
+30	697	541	156	86.75	2.513	0.0311	$9.5 \times 10^4$
+54	552	541	11	86.75	2.513	0.0311	$6.78 \times 10^3$
+72	561	541	20	86.75	2.513	0.0311	$1.21 \times 10^4$

TABLE 3.5  
THERMAL NEUTRON FLUX IN ROD DRIVE PIT

Run 4 - 64 Hr at 10.8 Mw (Normalized to Run 2, Channel 4)

Position	Activity, Cpm	Background, Cpm	Act, Net, Cpm	Decay Time, Hr	$e^{\lambda t}$	Foil Mass, Gm	Neutron Flux at 10 Mw, N/cm <sup>2</sup> sec
<u>WOOD SHIELD 4 In. x 4 In.</u>							
Left Top (TP 19)	396954	541	396413	86.50	2.51	.0317	$2.41 \times 10^8$
Left Mid	234553	541	234012	86.50	2.51	.0317	$1.42 \times 10^8$
Left Lower	73534	541	72993	86.50	2.51	.0317	$4.44 \times 10^7$
Bottom Mid	76925	541	76384	86.50	2.51	.0317	$4.63 \times 10^7$
Bottom Right	65118	541	64577	86.50	2.51	.0317	$3.92 \times 10^7$
<u>WATER BOX SHIELD FACE</u>							
Drive #3	390936	541	390395	86.50	2.51	.0317	$2.37 \times 10^8$
Drive #5	180746	541	180205	86.50	2.51	.0317	$1.09 \times 10^8$
Drive #7	115185	541	114644	86.50	2.51	.0317	$6.96 \times 10^7$
Bottom Right (TP 20)	95811	541	95270	86.50	2.51	.0317	$5.78 \times 10^7$













TABLE 3.6  
FAST NEUTRON FLUX IN SHIELD RINGS


Run 4 - 64 Hr at 10.8 Mw

Vertical Position From Core Centerline, In.	Activity, Cpm	Background, Cpm	Sulfur Mass, Gm	Neutron Flux at 10.8 Mw, N/cm <sup>2</sup> sec
<u>SHIELD CHANNEL #1</u>				
-29	56731/2	17	2.8689	$3.77 \times 10^8$
-12	395976/2	17	2.8689	$2.64 \times 10^9$
0	453925/2	17	2.8689	$3.46 \times 10^9$
+12	312455/2	17	2.8732	$2.08 \times 10^9$
+30	24605/2	17	2.8732	$1.63 \times 10^8$
<u>SHIELD CHANNEL #3</u>				
-29	5049/2	17	2.8739	$3.27 \times 10^7$
0	62966/2	17	2.8739	$4.19 \times 10^8$
+30	6925/5	17	2.8750	$1.84 \times 10^7$
<u>SHIELD CHANNEL #6</u>				
-29	1303/10	17	2.8750	$1.71 \times 10^6$
0	9234/10	17	2.8656	$1.23 \times 10^7$
+30	917/15	17	2.8656	$8.01 \times 10^5$











## 4.0 GAMMA RADIATION MEASUREMENTS

Previous measurements of the gamma radiation in the reactor shield were taken only at the elevation of the reactor core centerline, as reported in APAE-35. (1) In the present series of tests, film badges were mounted on aluminum strips at seven different elevations and inserted in the channels of the outer shield tank and axially above the reactor vessel in the inner-shield tank, in order to obtain a better indication of the dose rate distribution throughout the primary shield structure.

Radiation surveys were made in the rod drive pit on several occasions before, during and after the removal of SM-1 Core I. The dose rates showed no significant change, indicating that the core was not the source of this radiation.

Dose rate measurements were made 6 in. above the surface of the water in the spent fuel pit during handling and transfer of fuel elements.

### 4.1 GAMMA FLUX IN INSTRUMENT WELL A - TEST A404

Before beginning reactor operations on SM-1 Core II, a set of film badges mounted on an aluminum strip was inserted in instrument well A and irradiated for 8 hr with the reactor shut down (Run 0). The position of the films and the measured dose rate are shown in Table 4.1 and Fig. 4.1. Using the radial attenuation of dose rate from previous measurements reported in APAE-35, (1) background dose rates were determined out to shield channel 4, where they became negligible. This background correction, as shown in Table 4.1, was applied for the total exposure time in the reactor for succeeding runs; and it accounted for as much as 20% of the total dose for a few points.

For Run 1 at 11.1 kw for 20 min, another strip of films was exposed in well A. The dose rates are shown in Table 4.2 and Fig. 4.1. These were converted to a power level of 10 Mw and included with measurements in the shield channels, as reported in the following section.

### 4.2 GAMMA FLUX IN PRIMARY SHIELD - TEST A402

Film badge packets sealed in polyethylene bags were mounted on aluminum strips and inserted in the water channels between the shield rings in the outer shield tank. They were placed at seven elevations with respect to the core centerline: at -29 in., -12 in., 0 in., 12 in., 30 in., 54 in. and 72 in.



TABLE 4.1  
GAMMA BACKGROUND IN INSTRUMENT WELL A  
 Run 0 - 8 Hr Exposure Before Core Startup


Vertical Position From Core Centerline, In.	Total Dose, R	Exposure Time, Hr	Dose Rate, R/Hr	Calculated Shield Ring Dose Rate, R/Hr			
				#1	#2	#3	#4
-29	-	-	-	3.4	0.85	0.23	0.062
-12	130.0	8.0	16.3	22.1	5.57	1.49	0.407
0	150.0	8.0	18.8	25.5	6.42	1.71	0.470
+12	71.0	8.0	8.9	12.0	3.04	0.81	0.222
+30	11.0	8.0	1.4	1.9	0.48	0.13	0.035
+54	1.35	8.0	0.17	0.23	0.058	0.015	0.0042
+72	0.075	8.0	0.009	0.012	0.003	0.008	0.00002

TABLE 4.2  
GAMMA RADIATION IN INSTRUMENT WELL A

Run 1 - 20 Min at 11.1 Kw

Vertical Position From Core Centerline, In.	Total Dose, R	Background Exposure Time, Hr	Total Background Dose, R	Total Operating Dose, R	Exposure Time At Power, Hr	Operating Dose Rate, R/Hr	Average Power Level, Kw	Dose Rate at 10 Mw, R/Hr
-12	940.0	2.75	45.0	895.0	.333	2700	11.1	2,420,000
0	340.0	2.75	52.0	288.0	.333	865	11.1	780,000
+12	125.0	2.75	24.5	100.5	.333	300	11.1	271,000
+30	17.0	2.75	3.8	13.2	.333	40	11.1	35,700
+54	1.30	2.75	0.47	0.83	.333	2.5	11.1	2,240
+72	0.080	2.75	0.025	0.055	.333	0.165	11.1	149







Strips of film were inserted in shield channels 1, 2, 3 and 4 and irradiated at 11.1 kw for 20 min, Run 1. The dose rates, converted to 10 Mw power level, are shown in Table 4.3 and Figs. 4.2 and 4.3.

For Run #2 at 26.6 kw average for 8 hr, strips were inserted in shield channels 4, 5, 6 and 7. The results are shown in Table 4.3 and Figs. 4.2 and 4.3.

For Run #3 at 237 kw average for 60 hr, one strip of films was inserted close to the axis of the inner-shield tank above the reactor vessel cover. The positions and dose rates are shown in Table 4.4 and Fig. 4.4. Unfortunately, all of the films except two were damaged by water penetrating the polyethylene bags and were not readable.

These gamma radiation dose rates were all combined in Fig. 4.5 which shows contours of equal dose rate values through the primary shield structure.

The present gamma radiation values are higher than those previously shown in APAE-35, Fig. 2.4 by about a factor of three. The attenuation slope is similar to that obtained previously. The dose rates from this set of tests are higher than those shown in the calculated curve reported in APAE-35 by a factor of 1.5. This discrepancy is considered to be within the limits of error of both measurements and calculation.

#### 4.3 DOSE RATE AT VAPOR-CONTAINER SHIELD WALL

Two film packs were mounted inside the vapor-container wall; and two others, outside at points near the electrical penetrations, about 15 ft above the reactor core centerline. They were exposed for 10 days during which time the reactor operated for Run 4 at 10.8 Mw for 64 hr.

The operating dose rate inside the vapor container wall was measured as 0.54 and 0.56 R/hr. Outside the wall the dose rate was not detectable by the film badges there. These results are in reasonable agreement with those reported in APAE-18(4) and APAE-35. (1) Figure 4.6 shows the measured dose rate and a calculated attenuation curve.

#### 4.4 RADIATION SURVEYS IN ROD DRIVE PIT - TEST A407

The dose rate in the rod drive pit was measured on several occasions with portable radiation survey meter. Three surveys were made in April 1961 after the final shutdown of SM-1 Core I but before the core was removed. After the core was unloaded, the survey was repeated on May 4, and again on May 16, 1961 after the flushing and cleanup of crud in the bottom of the reactor vessel. Another survey was made on June 24, 1961 after completion of a two-day run at full power on Core II. This survey was repeated on October 20, 1961, four days after shutdown from four months of routine training operations on Core II.



There were no significant differences between any of these radiation surveys. Small variations could be attributed to location of the probe of the survey instrument. The measurements were also in reasonable agreement with previous surveys made from July to September 1959 and reported in APAE Memo 237. (3) These checks indicate there is no evidence of any serious increase in the radiation problem.

The highest readings were obtained at the water box shield face adjacent to the rod drive penetrations; and were made in the range of 10 to 20 R/hr. The leakage slots at the left side and bottom of the water box showed dose rates ranging from 1 to 3 R/hr. Two test points established at the upper left and lower right corners of the rod drive mounting plate usually read about 0.8 and 1.5 R/hr. The background in the accessible working space near the rod drive cables was 0.2 to 0.3 R/hr.

As mentioned in Section 3.2, the neutron flux in the rod drive pit was unexpectedly high. Activation of the steel face plate of the water box and the rod drive components may account for much of the radiation source. The reactor core is evidently not the source of this radiation. The water box is assumed to be empty, as the attempts to keep it full were discontinued a year or two before these tests.



TABLE 4.3  
GAMMA RADIATION IN SHIELD RINGS

Run 1 - 20 Min at 11.1 Kw

<u>Vertical Position From Core Centerline, In.</u>	<u>Total Dose, R</u>	<u>Background Exposure Time, Hr</u>	<u>Total Background Dose, R</u>	<u>Total Operating Dose, R</u>	<u>Exposure Time at Power, Hr</u>	<u>Operating Dose Rate, R/Hr</u>	<u>Average Power Level, Kw</u>	<u>Dose Rate at 10 Mw, R, Hr</u>
<u>SHIELD CHANNEL #1</u>								
-29	25.5	2.75	9.35	16.15	0.333	48.5	11.1	43,700
-12	290.0	2.75	60.7	229.30	0.333	688.0	11.1	619,000
0	460.0	2.75	70.0	390.0	0.333	1170.0	11.1	1,054,000
+12	230.0	2.75	33.0	197.0	0.333	590.0	11.1	532,000
+30	Damaged	2.75						
+54	2.15	2.75	0.630	1.520	0.333	4.56	11.1	4,100
+72	0.11	2.75	0.033	0.077	0.333	0.23	11.1	207
<u>SHIELD CHANNEL #2</u>								
-29	22.0	2.75	2.34	19.66	0.333	59.0	11.1	53,200
-12	86.5	2.75	15.30	71.2	0.333	213.5	11.1	193,000
0	115.0	2.75	17.7	97.3	0.333	292.0	11.1	263,000
+12	66.5	2.75	8.36	58.14	0.333	175.0	11.1	157,800
+30	7.2	2.75	1.32	5.88	0.333	17.7	11.1	15,950
+54	0.56	2.75	0.160	0.40	0.333	1.20	11.1	1,080
+72	0.015	2.75	0.008	0.007	0.333	0.021	11.1	19
<u>SHIELD CHANNEL #3</u>								
-29	5.45	2.75	0.630	4.82	0.333	14.45	11.1	13,050
-12	22.0	2.75	4.10	17.9	0.333	53.7	11.1	48,400
0	31.0	2.75	4.70	26.3	0.333	79.0	11.1	71,200
+12	Damaged	2.75	-	-	0.333	-	11.1	-
+30	2.475	2.75	0.355	2.120	0.333	6.36	11.1	5,730
+54	0.115	2.75	0.041	0.074	0.333	0.222	11.1	200
+72	0.015	2.75	0.002	0.013	0.333	0.039	11.1	35
<u>SHIELD CHANNEL #4</u>								
-29	Damaged	2.75	-	-	0.333	-	11.1	-
-12	Damaged	2.75	-	-	0.333	-	11.1	-
0	8.5	2.75	1.3	7.2	0.333	21.6	11.1	19,500
+12	5.6	2.75	0.61	5.0	0.333	15.0	11.1	13,500
+30	0.640	2.75	0.096	0.544	0.333	1.63	11.1	1,470
+54	0.075	2.75	0.011	0.064	0.333	0.190	11.1	171
+72	0.020	2.75	-	0.020	0.333	0.060	11.1	54




TABLE 4.3 (CONT'D)

Run 2 - 8 Hr at 26.6 Kw Average Power

Vertical Position From Core Centerline, In.	Total Dose, R	Background Exposure Time, Hr	Total Background Dose, R	Total Operating Dose, R	Exposure Time at Power, Hr	Operating Dose Rate, R/Hr	Average Power Level, Kw	Dose Rate at 10 Mw, R/Hr
<u>SHIELD CHANNEL #4</u>								
-29	84.25	12.5	0.78	83.47	8.0	10.4	26.6	3,910
-12	300.00	12.5	5.10	294.9	8.0	36.9	26.6	13,900
0	410.00	12.5	5.90	404.1	8.0	50.6	26.6	19,100
+12	240.00	12.5	2.80	237.2	8.0	29.7	26.6	11,200
+30	28.75	12.5	0.440	28.31	8.0	3.54	26.6	1,330
+54	1.40	12.5	0.052	1.35	8.0	0.169	26.6	64
+72	0.045	12.5	0.00025	0.045	8.0	0.0056	26.6	2.1
<u>SHIELD CHANNEL #5</u>								
-29	23.25	12.5	Negl.	23.25	8.0	2.91	26.6	1,090
-12	112.50	12.5	Negl.	112.50	8.0	14.10	26.6	5,300
0	112.50	12.5	Negl.	112.50	8.0	14.10	26.6	5,300
+12	50.00	12.5	Negl.	50.00	8.0	6.25	26.6	2,350
+30	6.15	12.5	Negl.	6.15	8.0	0.77	26.6	290
+54	0.23	12.5	Negl.	0.23	8.0	0.0288	26.6	11
+72	0.06	12.5	Negl.	0.06	8.0	0.0075	26.6	3
<u>SHIELD CHANNEL #6</u>								
-29	19.0	125	Negl.	19.0	8.0	2.38	26.6	895
-12	30.0	125	Negl.	30.0	8.0	3.75	26.6	1,410
0	34.25	125	Negl.	34.25	8.0	4.28	26.6	1,610
+12	Damaged	125	Negl.	-	8.0	-	26.6	-
+30	2.90	125	Negl.	2.90	8.0	0.363	26.6	136
+54	0.130	125	Negl.	0.130	8.0	0.0163	26.6	6.1
+72	-	125	Negl.	-	8.0	-	26.6	-
<u>OUTSIDE OUTER SHIELD</u>								
-29	2.050	125	Negl.	2.050	8.0	0.256	26.6	96
-12	2.350	125	Negl.	2.350	8.0	0.294	26.6	110
0	2.550	125	Negl.	2.550	8.0	0.319	26.6	120
+12	1.200	125	Negl.	1.200	8.0	0.150	26.6	56
+30	0.160	125	Negl.	0.160	8.0	0.020	26.6	7.5
+54	0.030	125	Negl.	0.030	8.0	0.0037	26.6	1.4
+72	0.025	125	Negl.	0.025	8.0	0.0031	26.6	1.2













TABLE 4.4  
GAMMA RADIATION IN INNER SHIELD TANK AXIS


Run 3 - 60 Hr at 237 Kw Average Power

Vertical Position From Core Centerline, In.	Total Dose, R	Background Exposure Time, Hr	Total Background Dose, R	Total Operating Dose, R	Exposure Time at Power, Hr	Operating Dose Rate, R/Hr	Average Power Level, Kw	Dose Rate at 10 Mw, R/Hr
72	Damaged	93.0	Negl.	-	60.0	-	237.0	-
83	Damaged	93.0	Negl.	-	60.0	-	237.0	-
95	1475.0	93.0	Negl.	1475.0	60.0	24.6	237.0	1,040
107	Damaged	93.0	Negl.	-	60.0	-	237.0	-
119	Damaged	93.0	Negl.	-	60.0	-	237.0	-
131	Damaged	93.0	Negl.	-	60.0	-	237.0	-
155	32.0	93.0	Negl.	32.0	60.0	0.534	237.0	22.5

















10.0

Figure 4.7. Test A408 Gamma Radiation Dose Rate From Spent Fuel Elements

Dose Rate 6" Above Water Surface (R/HR)

0.01



May 4, 1959  
Element CR-13 (Posn 64)  
58 Days after SD (10.5 MWY)

Apr. 27/61  
Element 48 (Posn 52, 61)  
16.5 Days after SD (18 MWY)

June 21/61  
Element CR-1-8  
72 Days after SD  
(7.5 MWY, Posn 42, 44)

Mar. 15/61  
Element 79 (Posn 43)  
320 Days after SD  
(16.4 MWY)

Water Depth Above Fuel Element  $\bar{z}$  (inches)

THIS PAGE  
WAS INTENTIONALLY  
LEFT BLANK



## 5.0 SPENT FUEL ELEMENT RADIATION MEASUREMENTS - TEST A408

The radiation level from spent fuel elements has been measured on several occasions. The element was suspended vertically from the handling tool and raised slowly toward the surface of the water in the spent fuel pit. The dose rate 6 in. above the water surface was measured for two or more readings in the range 0.1 to 2 R/hr; and the water depth was measured by scale markings on the handling tool.

The following elements were monitored:

<u>Date</u>	<u>Element</u>	<u>Position</u>	<u>Years in Reactor</u>	<u>MWYR Irradiation</u>	<u>Days Cooling Time</u>
3-15-61	79	43	3	16.4	320
4-27-61	48	52, 61	4	18.0	16.5
6-21-61	CR-1-S	42, 44	2	7.5	72.0
5-4-59	CR-13	64	2	10.5	58.0

The data for CR-13 was taken from APAE-55<sup>(5)</sup>, and is included in AP Memo-206. <sup>(6)</sup> The higher dose rates from this element may be attributed to the Co<sup>60</sup> in the flux suppressor comb at the top of the element. There was no cobalt in the flux suppressor on element CR-1-S.

The dose rates and attenuation curves are shown in Fig. 4.7. They are in reasonable agreement with calculated values. At water depth of approximately 4 ft, the fuel element is effectively a point source and the only significant gamma energies are in the range of 1.0 to 2.0 Mev. These are tabulated as fission product groups III, IV and V in a number of references, and their activity and attenuation can easily be calculated.

THIS PAGE  
WAS INTENTIONALLY  
LEFT BLANK



## 6.0 CONCLUSIONS

1. This series of tests complemented earlier measurements and extended knowledge of neutron flux and gamma radiation dose rate throughout the primary shield, shown by the contour plots in Fig. 3.6 and 4.5.
2. Neutron flux and gamma dose rates in the outer shield tank were higher than previously reported by a factor of 3 or more. The previous neutron activations were not converted to absolute flux values. Discrepancy between these and previous measurements is attributed either to systematic errors in power level, activity measurements, or data reduction. It is possible the present measurements were high by 50 percent, or a factor of 1.5 to 2, and the previous were low by 50 percent, or a factor of 2, which would account for the difference, but this is not fully explainable.
3. At the  $\text{BF}_3$  counter position in the bottom of the instrument well, the neutron flux is  $5.5 \times 10^9 \text{ n/cm}^2 \text{ sec}$  and the gamma radiation level is  $8 \times 10^5 \text{ R/hr}$  at a power level of 10 Mw. Raising the startup chamber 24 in. will reduce these levels to  $3 \times 10^9 \text{ n/cm}^2 \text{ sec}$  and  $9 \times 10^4 \text{ R/hr}$ , considering the sensitive area for neutrons to be 6 in. from the bottom and for gamma radiation to be the cable connector at the top of the chamber. Raising the chamber 72 in. (the total travel of the lifting mechanism) will reduce the levels to  $1.5 \times 10^7 \text{ n/cm}^2 \text{ sec}$  and  $1.7 \times 10^2 \text{ R/hr}$ . This information will provide understanding of the operation of the  $\text{BF}_3$  counter and provide evidence for malfunction analysis.
4. The high gamma radiation levels observed in the rod drive pit can be attributed to activation induced by the high neutron flux in this area.
5. Gamma dose rates measured at 6 in. above the water surface of the spent fuel pit during handling of spent fuel elements agreed reasonably well with calculations.

THIS PAGE  
WAS INTENTIONALLY  
LEFT BLANK



## 7.0 RECOMMENDATIONS

### 7.1 ADDITIONAL SHIELDING TESTS

1. Further studies of the neutron flux and gamma dose rates in the rod drive pit would be of value to compare with past data and thus establish the relative change in these levels. Tests A406 and A407 could be usefully repeated at annual intervals, and the high flux area should be more completely mapped.
2. Additional fast flux measurements using sulfur pellets should be obtained and used to extend this data closer to the reactor vessel and above the vessel head. These data would improve the fast flux mapping for radiation damage studies.

### 7.2 ANALYSIS OF SHIELDING DATA

1. Analysis of the data contained in this report should be performed. These analyses will aid in insuring the continued adequacy of the SM-1 shielding. Furthermore, the adequacy of the SM-1 shielding should be predicted with regard to future power levels and core loadings which may exceed present design values.
2. Effort should be directed toward identifying radiation sources in the rod drive pit area. Knowledge of these sources is prerequisite to optimum placement of additional shielding if a reduction of radiation levels in the rod drive area is desired.
3. Analysis of the spent fuel shielding data should establish minimum allowable water depths in the spent fuel tank. Minimum water shielding requirements during spent fuel transfer should be determined.
4. Analytical methods for predicting the neutron flux and gamma dose rates at "off-midplane" locations within the primary shield should be developed. The data from tests A401 and A402 should be used to determine the accuracy of the analytical model.

THIS PAGE  
WAS INTENTIONALLY  
LEFT BLANK



## 8.0 REFERENCES

1. Rosen, S. S., et al, "APPR-1 Research and Development Program, Shielding Experiments and Analyses, Task No. VI," APAE-35 and Supplement 1, October 15, 1958.
2. "Reactor Physics Constants," ANL-5800.
3. Obrist, C. H., et al, "SM-1 Research and Development Quarterly Report, July 1, 1959 to September 30, 1959," APAE Memo-237, January 15, 1960.
4. Meem, J. L., et al, "Initial Operation and Testing of the Army Package Power Reactor APPR-1," APAE-18, August 9, 1957.
5. Obrist, C. H., et al, "SM-1 Reactor Core Inspection at 2/3 Core Life," APAE-55, January 13, 1960.
6. MacKay, S. D., Tubbs, D. C., "SM-1 Research and Development Program Interim Report No. 2 on Core Measurements, Task No. VII," APAE Memo-206, June 30, 1959.